

SUPPLIER'S DECLARATION OF CONFORMITY

according to EN ISO/IEC 17050-1:2010

Name and address of the supplier issuing the declaration:

REGULUS spol. s r.o.

Do Koutů 1897/3,

CZ-143 00 Prague 4

Czech Republic

The identification of the product:

Draft Regulator, type: RT 4

Thermostatic Draft Regulator for solid fuel boilers, intended for boiler output control by opening or partially closing combustion air supply damper. Solid fuel boiler output is modified in order for the flow temperature to be kept at the value set by the knob. Suitable for heating water, water/glycol mixture up to 1:1 ratio or thermal oil as heat transfer fluids.

Regulation range: 30 - 90°C

Max. water temperature: 120°C

Max. ambient temperature: 60°C

Max. load on the chain: 100 – 1.000 g

Working position: horizontal, vertical

The object of the declaration described above is in conformity:

Directive 2001/95/EC of the European parliament and of the Council on general safety of product

PN 01:2007 Technical requirements for draft regulators testing

EN 303-5:2012 Heating boilers - Part 5: Heating boilers for solid fuels, manually and automatically stoked, nominal heat output of up to 500 kW - Terminology, requirements, testing and marking

Reference to the Test Report:

Test Report No. PBU-2/2012 on the 5. 3. 2012 issued by the Státní zdravotní ústav v Liberci

The date and place of issue of the declaration:

Prague, 01th January 2015



Mgr. Milan Brezina

quality manager

REGULUS spol. s r.o.
Do Koutů 1897/3
143 00 PRAHA 4
(7)